



ADDENDUM NOTICE

CEYLON PETROLEUM STORAGE TERMINALS LIMITED

**DESIGN, MANUFACTURE, SUPPLY, INSTALLATION, TESTING AND
COMMISSIONING OF INTERNAL FLOATING ROOFS FOR TANK NO. 09 AND 10
AT MUTHURAJAWELA TERMINAL - TENDER REF NO: KPR/23/2024**

This refers to the Invitation for Bids published in Daily News on 11.03.2024 in respect of above procurement.

The General Public is hereby informed that the **Addendum 01** to the above bidding documents have been issued.

The bidding details/Addendum 01 to the bidding documents are available on the CPSTL website www.cpstl.lk

Clarifications (if any) shall be sought from the Manager Procurement on **Tel: +94-11-2572156/ +94-11-2547238, Fax: +94-11-2074299, Email: procure@cpstl.lk**.

**The Chairman
Department Procurement Committee (Minor)
C/o Manager Procurement
Ceylon Petroleum Storage Terminals Limited
Procurement Function
01st Floor, New Building
Kolonnawa, Wellampitiya
Sri Lanka.**

ADDENDUM 01 - TO THE BIDDING DOCUMENT



CEYLON PETROLEUM STORAGE TERMINALS LIMITED

BIDDING DOCUMENT
INTERNATIONAL COMPETITIVE BIDDING (ICB)

**DESIGN, MANUFACTURE, SUPPLY, INSTALLATION, TESTING AND
COMMISSIONING OF INTERNAL FLOATING ROOFS FOR TANK NO. 09 AND 10
AT MUTHURAJAWELA TERMINAL**

TENDER REF NO: KPR/23/2024

ADDENDUM 01

**INSTRUCTIONS TO BIDDERS, CONDITIONS OF CONTRACT AND
SCOPE OF SUPPLY & SERVICES**

The Chairman
Department Procurement Committee (Minor)
C/o Manager Procurement
Ceylon Petroleum Storage Terminals Limited
Procurement Function
01st Floor, New Building
Kolonnawa, Wellampitiya
Sri Lanka

TEL : +94-11-2572156/ +94-11-2547238
FAX : +94-11-2074299
E-Mail : procure@cpstl.lk

ADDENDUMS TO THE CONDITIONS OF CONTRACT – SECTION 02

Item No.	Conditions of Contract (COC) Clause No.	Revision
01	INSPECTION & TESTING Clause 2.3/ Page No. 26	The IFR shall be tested as per API 650 12th edition by the manufacturer and witnessed by the reputed Independent Third Party Inspection Company approved by CPSTL together with two (02) CPSTL engineers at the manufacturer's fabrication shop. All test certificates shall be provided during pre-shipment inspection. Material Test certificates shall be in accordance with EN 10204 type 3.1.

ADDENDUMS TO THE SCOPE OF SUPPLY AND TECHNICAL SPECIFICATIONS – SECTION 03

Item No.	Scope of Supply and Technical Specifications Clause No.	Revision
01	SCOPE OF SUPPLY BY THE SUPPLIER Clause 3.3.5/ Page No. 40	Third party inspection of material test certificates, shop fabrication and testing of each internal floating roof by a reputed third-party inspection company approved by CPSTL, witnessed by two CPSTL engineers at the manufacturer's shops and submission of third party inspection report to CPSTL. <i>Material Test certificates shall be in accordance with EN 10204 type 3.1.</i>